



JACKSONVILLE WASTEWATER UTILITY

248 Cloverdale Rd.
Jacksonville, AR 72076
501-982-0581

No. 06- 0086

RESIDENTIAL OR COMMERCIAL BUILDING SEWER CONNECTION PERMIT

Street Address 105 Franklin Street

Legal Description Lot 3 Graham settlement

Facility to be connected to sewer:



Single Family Residence X *Multi-family Residential _____ Units _____

*Commercial Installation _____ Description: _____

Water Meter (s) Size 5/8

* Commercial installations, and multi-family installations of more than 4 dwelling units must be accompanied by a site plan showing the proposed building sewer.

Installation by West Lake Plumbing



APPRO
Jacksonville Wastewater Utility

By: Darryl Vickers

Date: 07-31-06

Darryl - West Lake
JWU - Inspected
12-15-06

Inspected - rejected
Final Inspection - 12/18/06

PERMIT NO. 06-0086
JACKSONVILLE WASTEWATER UTILITY
SERVICE INSPECTION
DATE: 12-18-06



OWNER:

ADDRESS:

PLUMBER:

SERVICE LINE: OK ☐ REJECTED ☒ REASON: Pipe not bedded

SIGNED: Darryl Vickers