



JACKSONVILLE WASTEWATER UTILITY

248 Cloverdale Rd.
Jacksonville, AR 72076
501-982-0581

No. 07-0020

RESIDENTIAL OR COMMERCIAL BUILDING SEWER CONNECTION PERMIT

Street Address 1201 Stanphill

Legal Description _____

Facility to be connected to sewer:

Single Family Residence ☒ *Multi-family Residential _____ Units _____

*Commercial Installation _____ Description: New Connection

Water Meter (s) Size 5/8"

* Commercial installations, and multi-family installations of more than 4 dwelling units must be accompanied by a site plan showing the proposed building sewer.

Sewer line installation by Mark's Plumbing Brad
551-8916

Address _____

General Contractor _____

Address _____

In consideration of _____

1. To accept _____

2. To maintain public sewer _____

3. To notify the public _____

Fees: _____



JACKSONVILLE WASTEWATER UTILITY SERVICE INSPECTION

PERMIT NO. 07-0020

DATE: 2-27-07

OWNER: _____

ADDRESS: 1201 STANPHILL RD.

PLUMBER: MARK'S PLUMBING

SERVICE LINE: OK ☐ REJECTED ☒ REASON: Pipe not bedded

SIGNED: Darryl Pickens

Tap Charge \$ _____

Receipt No. _____

Inspector _____

Street _____

APPLICANT _____

Signed _____

☐ Plumber

☐ General Contractor

☒ Owner

APPROVED _____

Jacksonville W _____

By: [Signature] STANPHILL RD.

