



# JACKSONVILLE WASTEWATER UTILITY

248 Cloverdale Rd.  
Jacksonville, AR 72076  
501-982-0581

No. 06- 0136

## RESIDENTIAL OR COMMERCIAL BUILDING SEWER CONNECTION PERMIT

Street Address 1301 School Drive

Legal Description \_\_\_\_\_

Facility to be connected to sewer:

Single Family Residence ✓ \*Multi-family Residential \_\_\_\_\_ Units \_\_\_\_\_

\*Commercial Installation \_\_\_\_\_ Description: repair

Water Meter (s) Size 5/8

Commercial installations, and multi-family installations of more than 4 dwelling units must be accompanied by a site plan showing the proposed building sewer.

Sewer line installation by Self Jory Taylor

Address \_\_\_\_\_

General Conditions \_\_\_\_\_

Address \_\_\_\_\_

In consideration of \_\_\_\_\_

1. To accept \_\_\_\_\_

2. To maintain \_\_\_\_\_ public \_\_\_\_\_

3. To notify \_\_\_\_\_ to the \_\_\_\_\_

Fees: \_\_\_\_\_



### JACKSONVILLE WASTEWATER UTILITY SERVICE INSPECTION

PERMIT NO. 06-0136

DATE: 4-05-06

OWNER: Jory Taylor

ADDRESS: 1301 School Dr

PLUMBER: Owner

SERVICE LINE: OK ☐ REJECTED ☒ REASON: NO 2-WAY CLEAN-OUT


SIGNED: Darryl Pickens

Tap Charge \$ \_\_\_\_\_ Receipt No. \_\_\_\_\_

APPLICANT  
Signed \_\_\_\_\_

APPROVED  
Jackson \_\_\_\_\_

By: \_\_\_\_\_



Darryl

Inspector