



JACKSONVILLE WASTEWATER UTILITY
SERVICE INSPECTION

PERMIT NO. _____

DATE: 4-19-01

OWNER: _____

ADDRESS: 36 Charlotte

PLUMBER: Owner

SERVICE LINE: OK ☐ REJECTED ☒

REASON: Defective Plumbing

Water tight

SIGNED _____



JACKSONVILLE WASTEWATER UTILITY

248 Cloverdale Road • P.O. Box 69
Jacksonville, AR 72078-0069
982-0581

No. 01073

IDENTIAL OR COMMERCIAL BUILDING SEWER CONNECTION PERMIT

Address _____

36 Charlotte Cir

Description _____

Is connected to sewer: _____

Is Residence ☒

*Multi-family Residential _____

Units _____

Is Installation _____

Description: repair cleanout cap


Is (s) Size _____

5/8"

Special installations, and multi-family installations of more than 4 dwelling units must be approved by a site plan showing the proposed building sewer.

Installation by _____

Bob's Plumbing
Homeowner



PERMIT NO. _____

JACKSONVILLE WASTEWATER UTILITY
SERVICE INSPECTION

DATE: 3-22-01

OWNER: _____

ADDRESS: 36 Charlotte

PLUMBER: Bill's Plumbing

SERVICE LINE: OK ☐ REJECTED ☒

REASON: No 2-way

cleanout

SIGNED _____

Section Fee

\$ 4.00

Receipt No. _____

Other Fees

\$ 6.00 second inspection

\$ 6.00 third inspection

2867
2941
2949

Plumbing Contractor _____

General Contractor _____

Owner (Address) _____

982-1713

Wastewater Utility

Keith Reed

Date: _____

3-8-01