



No. 05-0143

JACKSONVILLE WASTEWATER UTILITY

248 Cloverdale Road • P.O. Box 69
Jacksonville, AR 72078-0069
982-0581

RESIDENTIAL OR COMMERCIAL BUILDING SEWER CONNECTION PERMIT

Street Address 405 W. Valentine RdLegal Description Lot 39 Clover Ridge Pk I-N

Facility to be connected to sewer:

Single Family Residence ☒ *Multi-family Residential _____ Units _____

*Commercial Installation _____ Description: _____

Water Meter (s) Size 3/8

* Commercial installations, and multi-family installations of more than 4 dwelling units must be accompanied by a site plan showing the proposed building sewer.

Sewer line installation by Gray Plumbing - A.M. PlumbingAddress 240 Wenlock Cove, Cabot 72023

General Cont

Address P

In considerati

1. To accept

2. To maintain
public sew3. To notify the
to the pub

Fees: Con

JACKSONVILLE WASTEWATER UTILITY
SERVICE INSPECTIONDATE: 8-11-05

OWNER: _____

ADDRESS: 405 W. Valentine RdPLUMBER: A.M. PlumbingSERVICE LINE: OK ☐ REJECTED ☒ REASON: Need 2-way cleanoutSIGNED: Darryl Pickens

Tap Cl

Inspec

Street

APPLICANT

Signed _____

- ☐
- Plu
-
- ☐
- Ger
-
- ☐
- Ow

APPROVED
Jacksonville WaBy: [Signature] Date: 4-28-05