

Jacksonville Wastewater Utility
Effective Building Sewer Report

How Located	Address
Smoked	Max Howell Place

Location

The following locations have cleanout caps missing or broken

#4 A & B S. Simmons
#3 A S. Simmons rev
#7 B S. Simmons
#6 A+B N. Simmons
#4 B N. Simmons
#16 B Whatley Loop
#20 B Whatley Loop
#13 B Whatley Loop
#1 B Whatley Loop DRAWER BROKE
#5 A D Hamm Court

Completed
8/27/92

inspected
9-4-92
D. Dabiel

Comments

Located By:	Gary Gaebel	Engineer	Robert Adams
Date:	8-19-92	Date	8-24-92

If you have any questions concerning this drawing, please contact
Jacksonville Wastewater Utility Engineering at 982-0581. Thank you.