



No. 06- 0123

# JACKSONVILLE WASTEWATER UTILITY

248 Cloverdale Rd.  
Jacksonville, AR 72076  
501-982-0581

## RESIDENTIAL OR COMMERCIAL BUILDING SEWER CONNECTION PERMIT

Street Address 921 North 1st Street

Legal Description O'Reilly (new location)

Facility to be connected to sewer:

Single Family Residence \_\_\_\_\_ \*Multi-family Residential \_\_\_\_\_ Units \_\_\_\_\_

\*Commercial Installation ✓ Description: new service

Water Meter (s) Size 1 inch


\* Commercial installations, and multi-family installations of more than 4 dwelling units must be accompanied by a site plan showing the proposed building sewer.

Sewer line installation by Building & Utility Northside Plumbing

Schedule 40 PVC  
Used, Depth of  
~3', PVC to Stub  
w/ Ductile Iron  
Coupling

Cast Iron  
by Previous  
Tie in

921 N. 1st



## JACKSONVILLE WASTEWATER UTILITY SERVICE INSPECTION

PERMIT NO. 06-0123

4-18-06

IR: \_\_\_\_\_

ESS: 921 N. First Street

BER: Northside Plumbing

CE LINE: OK ☐ REJECTED ☐ REASON: \_\_\_\_\_

Connection to manhole must  
be approved material.

Not cast iron. SIGNED: Jon Byham

\$ 100.00 Receipt No. 9700

\$ \_\_\_\_\_ Receipt No. \_\_\_\_\_

\$ 12.00 4/7/06 Receipt No. 2356

\$ 12.00 4/19/06 Receipt No. 2374

\$ \_\_\_\_\_ Receipt No. \_\_\_\_\_

North 1st Street

APPROVED  
Jacksonville Wastewater Utility

By: Jessica Kerdink Date: 2/17/06

Jon Rattal  
Jon Rattal  
4/19/06

Inspected  
4-19-06