



JACKSONVILLE WASTEWATER UTILITY
248 Cloverdale Rd.
Jacksonville, AR 72076
501-982-0581

No. 06- 0289

RESIDENTIAL OR COMMERCIAL BUILDING SEWER CONNECTION PERMIT

Street Address 1009 + 1011 Gina Circle

Legal Description Lot 3 Eastview Add.

Facility to be connected to sewer:

Single Family Residence _____ *Multi-family Residential X Units _____

*Commercial Installation _____ Description: _____

Water Meter (s) Size 3/8

* Commercial installations, and multi-family installations of more than 4 dwelling units must be accompanied by a site plan showing the proposed building sewer.

Sewer line installation by Mantooth Plumbing

Address _____

General _____

Address _____

In consid _____

1. To ac _____

2. To ma
public _____

3. To no
to the _____

Fees: _____



JACKSONVILLE WASTEWATER UTILITY
SERVICE INSPECTION

PERMIT NO. 06-0289

DATE: 12-18-06

OWNER: _____


ADDRESS: 1009 + 1011 GINA CIR

PLUMBER: MANTOOTH PLUMBING

SERVICE LINE: OK ☐ REJECTED ☒ REASON: CAST IRON PIPE

SIGNED: Darryl Pickens

APPLIC
Signed _____



APPROVED
Jacksonville Wastewater Utility

By: _____ Date: 10-04-06

Inspected - rejected
Final Inspection - 12/18/06