



JACKSONVILLE WASTEWATER UTILITY

248 Cloverdale Rd.
Jacksonville, AR 72076
501-982-0581

No. 06- 0276

RESIDENTIAL OR COMMERCIAL BUILDING SEWER CONNECTION PERMIT

Street Address 1021 + 1023 Gina Circle

Legal Description Lot 6 Eastview Add PH VTB

Facility to be connected to sewer:

Single Family Residence _____ *Multi-family Residential X Units _____

*Commercial Installation _____ Description: _____

Water Meter (s) Size 3/8

* Commercial installations, and multi-family installations of more than 4 dwelling units must be accompanied by a site plan showing the proposed building sewer.

Sewer line installation by Loroke Co - Mantooth Plmng

Address _____

General _____

Address _____

In con _____

1. To _____

2. To put _____

3. To to t _____

Fees: _____



JACKSONVILLE WASTEWATER UTILITY SERVICE INSPECTION

PERMIT NO. 06-0276

DATE: 11-01-06

OWNER: _____


ADDRESS: 1021 + 1023 GINA CIR

PLUMBER: MANTOOTH PLUMBING

SERVICE LINE: OK ☐ REJECTED ☒ REASON: Pipe not bedded

SIGNED: Darryl Pinkus

APPLICANT
Signed _____



APPROVED
Jacksonville Wastewater Utility

By: _____

Date: 08-29-06

Inspected - Rejet
11-1-06

Inspected
11-1-06